



mantova



Production capacity	
	CC1 and CC2 Combined Cycle: electrical power 390 MWe thermal power 683 MWt
	B6 reserve boiler : electrical power 56 MWe thermal power 258 MWt
System types	
	Two combined cycles with natural gas
	One reserve conventional cycle with natural gas
Year the combined cycles became operational	
	2005
Fuels	
	Natural gas
Products	
	Electricity
	Technological steam
Other services and products	
	Providing heat for the district heating grid
Eni companies served at the site	
	Versalis
Address	
	via Taliaccia 14 46100 Magtova (MN)

certification

EMAS GESTIONEAMBIENTALE VERIFICATA Re gn.IT-001459

*

via Taliercio, 14 - 46100 Mantova (MN)